



Scott Walker, Governor
Dave Ross, Secretary

January 25, 2016

CUST ID No. 1315288

DAVID URBAN
MCC INC
N7820 OLD HWY 141
CRIVITZ WI 54114

PLAN APPROVAL EXPIRES: 01/30/2021

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: MCC INCORPORATED
Product Name: SEPTIC/SEPTIC, SEPTIC/PUMP, HOLDING OR PUMP (trans id 2657427)
Model Number(s): 1200/800 (804/1260 gals. actual capacity)
(49.5 IN. L.L., 25.5/16.3 GAL/IN., 48 IN. MAX. DEPTH OF BURY, 991 G.P.D.
WHEN USED AS A SEPTIC/SEPTIC TANK OR 605 G.P.D. WHEN USED AS A
SEPTIC/PUMP TANK BASED ON A 3 YR. SERVICE INTERVAL FOR
RESIDENTIAL WASTEWATER; TANK DIMENSIONS (OD) = 145 IN. L X 78 IN.
W X 66.5 IN. H)
Product File No: 20160009

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of January 2021.**

This approval supersedes the approval issued on 5/3/2011 under product file number 20110156.

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use the following:
 - 3/4" diameter opening in the access riser.
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product has an effluent filter installed in an interior wall, the space between the top of the interior wall and bottom of the tank's cover must be sealed with a material that will withstand the environment in the tank and in a manner that will prevent waste from passing over the interior wall.

Identification Numbers
Transaction ID No. 2657427
Site ID No.
Please refer to both identification numbers, above, in all correspondence with the agency.

- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 greater than 30 mg/L but less than or equal to 220 mg/L, TSS greater than 30 mg/L but less than or equal to 150 mg/L and F.O.G. less than or equal to 30 mg/L.
- **BEDDING AND BACKFILL:** Tank bedding must be 3 in. of compacted sand, gravel or lime rock of which 100% will pass through ½-inch screen. Backfill material must be material that 100% will pass through a 4-inch screen and tamped into place.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.
POWTS Product Reviewer
phone: (608) 267-5265
fax: (608) 267-9723
email: glen.jones@wi.gov

The DSPS is committed to service excellence. Visit our survey at:

www.surveymonkey.com/s/dspsiscustomersatisfaction